



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПОССП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – HYPBCПCРБ – 3995

Issued pursuant to Art. 14, par.1 and par. 2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

WELDABLE REINFORCING STEEL

class B 500 C on bars and coils

used for the reinforcement of concrete with nominal diameter

and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

placed on the market by

DILER IRON & STEEL INC.

DILOVASI ÇELİK TESİSLERİ, GEBZE, KOCAELİ-TURKIYE

manufactured by

DILER IRON & STEEL INC.

DILOVASI ÇELİK TESİSLERİ, GEBZE, KOCAELİ-TURKIYE

This certificate certifies that the product has been evaluated
and meets national requirements set out in

BDS 9252: 2007

*and item 1.1 of Annex 3 to item 2 of Order № RD-02-14-1329 from 03.12.2015,
the Minister of Regional Development and Public Works,
amendment and addition by Order № RD-02-14-590 from 05.07.2017*


The certificate was issued on **09/01/2024** cancel the **Certificate № 14-HYPBCПCРБ-3665** from **25/05/2022** and remains valid for three years until **08/01/2027**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia

Date: 09/01/2024

Director of "Conformity Assessment" Dept.

/T. Lyubenova/






Supplement № 1
to Certificate of Conformity № 14- HYPBCПCРБ-3995

1. Nominal diameter:

- Bars with nominal diameter №: 8/10/12/14/16/18/20/22/25/28/32/36/40
- Coils* with nominal diameter №: 8/10/11/12

**Coils with nominal diameter > 12 mm are produced at the request of the client, according to item 8.3 of BDS 9252:2007*

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Yield strength, R_e	min 500 MPa According to table № 4 of BDS 9252:2007
Tensile strength, R_m	min 575 MPa According to table № 4 of BDS 9252:2007
R_m / R_e	min 1,15, max. 1,35 According to table № 4 of BDS 9252:2007
Elongation A_{gt} , %	min 7,5 % According to table № 4 of BDS 9252:2007
Bending at 180°	without cracks According to table № 4 of BDS 9252:2007
Bending/rebinding, at 90°	without cracks According to table № 4 of BDS 9252:2007
Linear mass, kg / m	$0,395 \div 9,856$ According to table № 1 of BDS 9252:2007
Cross-sectional area A_n , mm	$50,3 \div 1256,6$ According to table № 1 of BDS 9252:2007
Relative area of the ribs, f_r	$6 < d \leq 12$ mm: f_r min. 0,040 $d > 12$ mm: f_r min. 0,056 According to table № 2 of BDS 9252:2007
Profile	 According figure № 3 of BDS 9252:2007
Fatigue strength, n number of cycles N (when required)	NA
Chemical composition Weldability (carbon equivalent), C_{eq}	max. 0,50 -for the heate max. 0,52 – for the product According to table. № 3 of BDS 9252:2007

Place: Sofia
Date: 09/01/2024

Director of "Conformity Assessment" Dept.

(Signature)
/T. Lyubenova/

