



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПССП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – НУРВСПСРБ – 3932

Issued pursuant to Art. 14, par.1 and par. 2 of the Regulation № РД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

HOT ROLLED PLAIN REINFORCING STEEL

class B235 on bars and on coils

used for the reinforcement of concrete with nominal diameter

and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

placed on the market by

DILER IRON & STEEL INC.

DILOVASI ÇELİK TESİSLERİ, GEBZE, KOCAELİ-TURKIYE

manufactured by

DILER IRON & STEEL INC.

DILOVASI ÇELİK TESİSLERİ, GEBZE, KOCAELİ-TURKIYE

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS 4758: 2008

*and item 1.1 of Annex 3 to item 2 of Order № RD-02-14-1329 from 03.12.2015,
of the Minister of Regional Development and Public Works,
amendment and addition by Order № RD-02-14-590 from 05.07.2017*

The certificate was issued on **09.01.2024** cancel the Certificate № 14-НУРВСПСРБ-3496 from 17.12.2020 and remains valid for three years until **08.01.2027**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia

Date: 09.01.2024

Director of "Conformity Assessment" Dept.

[Signature]
/T. Lyubenova/





1. Nominal diameter:

- Bars and Coils with nominal diameter №: 8 /10 /12/ 14/16/18

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Yield strength, R_e	min 235 MPa According to table № 2 of BDS 4758:2008
Tensile strength, R_m	min 370 MPa According to table № 2 of BDS 4758:2008
Elongation A_5 , %	min 25 % According to table № 2 of BDS 4758:2008
Bending at 180 °	without cracks According to table № 2 of BDS 4758:2008
Linear mass, kg / m	0,617÷1,997 According to table № 3 of BDS 4758:2008
Cross-sectional area A_n , mm	50,3÷254,5 According to table № 3 of BDS 4758:2008
Chemical composition Weldability (carbon equivalent), C_{eq} , %	No requirements

Place: Sofia

Date: 09.01.2024

Director of "Conformity Assessment" Dept.

/T. Lyubanova/

